



## Report Committee of Adjustment

**Filing Date:** October 17, 2023  
**Hearing Date:** November 14, 2023  
**File:** A-2023-0330  
**Owner/  
Applicant:** Gorgi Stojanovski  
**Address:** 7 Deerpark Crescent  
**Ward:** WARD 1  
**Contact:** Aferdita Dzaferovska, Planning Technician

---

### Recommendations:

1. That application A-2023-0330 be refused.
- 

### Background:

#### Existing Zoning:

The property is zoned 'Residential Semi-Detached C Special Section 3172 (R2C-31270)', according to By-law 270-2004, as amended.

#### Requested Variances:

The applicant is requesting the following variances:

1. To permit a proposed exterior stairway leading to a below grade entrance in a required side yard, whereas the by-law does not permit exterior stairways constructed below established grade in the required interior side yard; and
2. To permit an interior side yard setback of 0.41 metres to a proposed exterior stairway leading to a below grade entrance, whereas the by-law requires a minimum interior side yard setback of 1.2 metres.

## **Current Situation:**

### **1. Maintains the General Intent and Purpose of the Official Plan**

The subject lands are designated 'Residential' in the Official Plan and 'Low Density Residential' in the Brampton Flowertown Secondary Plan (Area 6). The new Council approved Brampton Plan Schedule 2 designates the property 'Neighbourhoods'. The requested variances are not considered to have significant impacts within the context of the Official Plan and Secondary Plan policies, and is considered to maintain the general intent and purpose of the Official Plan.

### **2. Maintains the General Intent and Purpose of the Zoning By-law**

The property is zoned 'Residential Semi-Detached C Special Section 3172 (R2C-3172)', according to By-law 270-2004, as amended.

Variance 1 is requested to permit a proposed exterior stairway leading to a below grade entrance in a required side yard, whereas the by-law does not permit exterior stairways constructed below established grade in the required interior side yard.

Variance 2 is requested to permit an interior side yard setback of 0.41 metres to a proposed exterior stairway leading to a below grade entrance, whereas the by-law requires a minimum interior side yard setback of 1.2 metres.

When completing a review to determine whether the location of a below grade entrance and resulting interior side yard setback are appropriate, Staff look to ensure that its location will not contribute to disturbance onto adjacent properties by way of drainage or access. Staff have reviewed the application and have concerns relating to drainage. As per the City of Brampton Subdivision Manual, the location of the proposed below grade entrance is not considered to provide sufficient space for drainage on the property. Engineering Staff provided that they do not support the proposed below grade entrance due to the 1.2m side yard setback being required for drainage purposes in accordance with the City of Brampton rear to front drainage design requirements. Staff have communicated the matter with the applicant.

The requested variances are not considered to maintain the general intent and purpose of the Zoning By-law.

### **3. Desirable for the Appropriate Development of the Land**

The proposed exterior stairway leading to a below grade entrance in a required side yard is anticipated to significantly affect the subject property and adjacent property by way of drainage. The location of the proposed below grade entrance is not considered to provide sufficient space for drainage on the property. The requested variances are not considered desirable for the appropriate development of the land.

#### 4. Minor in Nature

The proposed location of the below grade entrance and reduced interior side yard setback are anticipated to have a negative disturbance by way of drainage. Staff have determined that sufficient space has not been provided to allow for drainage and therefore, it is anticipated to cause issues on the abutting property and on the subject lands. As such, Variances 1 and 2 are not considered minor in nature.

Respectfully Submitted,

*Aferdita Dzaferovska*

Aferdita Dzaferovska, Planning Technician

APPENDIX A – Site Visit Photos

